




GREENGUARD CERTIFICATION TEST REPORT					
<b>Customer Information</b>	ARCOSA SPECIALTY MATERIALS STEVEN BUTLER 1550 DOUBLE DRIVE NORMAN OK 73069				
<b>Product Description</b>	AccuCrete Primer/Sealer 8818				
<b>Test Group</b>	Primer Sealer - 01				
<b>Category</b>	Flooring				
<b>Test Type</b>	Initial				
<b>Test Method</b>	UL 2821 "GREENGUARD Certification Program Method for Measuring and Evaluating Chemical Emissions From Building Materials, Finishes and Furnishings Using Dynamic Environmental Chambers"				
	<b>Environment</b>	<b>TVOC</b>	<b>Formaldehyde</b>	<b>Total Aldehydes</b>	<b>CREL/TLV</b>
<b>GREENGUARD</b>	Office	✓	✓	✓	✓
<b>GREENGUARD Gold</b>	Office	✓	✓	✓	✓
	Classroom	✓	✓	✓	✓
✓ - meets criteria; X - over criteria					
<b>Authorized by</b>	 Allyson M. McFry Chemistry Laboratory Director				

MODELING FOR PREDICTED AIR CONCENTRATION					
Certification Program	Environment Basis	Modeling Basis	Surface Area (m <sup>2</sup> )	Room Volume (m <sup>3</sup> )	ACH (1/hr)
<b>GREENGUARD and GREENGUARD Gold Office</b>	CDPH/EHLB/Standard Method	floor	11.1	30.6	0.68
<b>GREENGUARD Gold Classroom</b>	CDPH/EHLB/Standard Method	floor	89.2	231	0.82

Note that certain environments and/or modeling scenarios may prevent assessment of low level CREL and TLV analytes due to the emissions being below the lower LOQ (0.04 µg). For example, benzene ½ CREL is 1.5 µg/m<sup>3</sup>.

**PHOTOGRAPH OF SAMPLE**

